

Duets Tactiles Glow Installation Instructions

Requirements for UL Compliance

- The minimum functional width (stroke) of luminous letters and artwork is 0.25" (6.35mm)
- The maximum spacing between luminous segments is not to exceed 12" (305mm)
- All luminous segments should be installed on a clean, flat surface with appropriate adhesive
- For use as floor proximity path markers, the mounting height is to be in accordance with local and national codes but is not to exceed 18" (45.7 cm) above finished floor height
- The spacing between the corner of a change in direction of the path of egress and the luminous segment is not to exceed 4" (10.2 cm)
- Directional indicators (arrows or the like) are to be mounted at changes in direction and at locations intended to lead persons out of, or from entering a dead end corridor



WARNING

Using Glow Sheet without adequate ambient illumination may cause it to not function properly.



Ambient Lighting Requirements

Glow letters and artwork require a minimum of 1 foot-candle (10.76 lux) of ambient illumination from LED, fluorescent or incandescent lighting to work effectively. The ambient illumination should be controlled by authorized personnel.



Maintenance and Cleaning

Keep Glow Sheet clean and clear of dust, debris or obstructions for optimal performance. Refer to applicable local or national model codes for required inspections of egress path markings.